

231-773-5998 Phone 888-979-4469 Fax www.trace-labs.com

February 14, 2024

Mr. Michael Eslick Public Health Muskegon County 209 E. Apple Avenue Muskegon, MI 49442

Phone: (231) 724-1253 Fax: (231) 724-1251

RE:	Trace Project	24B0567
	Client Project	North Lake - Dune Harbor Park

Dear Mr. Eslick:

Enclosed are your analytical results. The results of this report relate only to the samples listed in the body of this report.

All reports were examined through Trace's validation process to ensure that requirements for quality and completeness were satisfied. All reported analytical results were obtained in accordance with the methods referenced on the reports. Every practical effort was made to meet the reporting limit specifications for this work, however, some results may have raised reporting limits to correct for percent solids.

For clients that require NELAP Accreditation, Trace certifies that these test results meet all requirements of the NELAP Standard, except for those analytes with a "N" notation. These analytes have not been evaluated by NELAP at Trace's discretion and will not be reported unless requested by client.

If you have questions concerning this report, please contact me at 231.773.5998 or by email at dhilleary@trace-labs.com.

Sincerely,

Dia Hillar

Drew Hilleary Project Manager Enclosures



NJDEP Accreditation No. MI008

# STATE OF MICHIGAN LABORATORY ID: 8001



231-773-5998 Phone 888-979-4469 Fax www.trace-labs.com

#### SAMPLE SUMMARY

Trace Project ID:	24B0567
Client Project ID:	North Lake - Dune Harbor Park

Trace ID	Sample ID	Matrix	Collected By	Date Collected	Date Received		
24B0567-01	Sample	Surface Water	ME	02/09/24 14:00	02/09/24 14:39		

# **CERTIFICATE OF ANALYSIS**

#### STATE OF MICHIGAN LABORATORY ID: 8001



231-773-5998 Phone 888-979-4469 Fax www.trace-labs.com

# AN EXPLANATION OF TERMS AND SYMBOLS WHICH MAY OCCUR IN THIS REPORT

#### DEFINITIONS

MS	Matrix Spike
RPD	Relative Percent Difference
DUP	Matrix Duplicate
RDL	Reporting Detection Limit
MCL	Maximum Contamination Limits as set by the Federal Safe Drinking Water Act
Not Detected	Indicates that the compound was not detected at the RDL
TNTC	Too Numerous To Count

# Results that are reported in bold or red have equalled or exceeded the MCL.

# **CERTIFICATE OF ANALYSIS**

#### STATE OF MICHIGAN LABORATORY ID: 8001



231-773-5998 Phone 888-979-4469 Fax www.trace-labs.com

#### ANALYTICAL RESULTS

#### Sample Location: North Lake - Dune Harbor Park

Trace ID: 24B0567-01 Sample Point Description: Sample			Date Collected: Date Received:		02/09/24 14:00 02/09/24 14:39				
PARAMETERS	RESULTS	RDL	UNITS	PREPARED	BY	ANALYZE	D BY	NOTES	MCL
METALS, TOTAL									
Analysis Method: EPA 200.7 Rev. 4.4 Batch: T147101									
Calcium	30	1.0	mg/L	2/12/24 8:3	9 fs	2/13/24 1	1:55 jma		No MC
Iron	Not Detected	0.20	mg/L	2/12/24 8:3	9 fs	2/13/24 1	1:55 jma		No MC
Magnesium	11	1.0	mg/L	2/12/24 8:3	9 fs	2/13/24 1	1:55 jma		No MC
Manganese	Not Detected	0.020	mg/L	2/12/24 8:3	9 fs	2/13/24 1	1:55 jma		No MC
Sodium	25	1.0	mg/L	2/12/24 8:3	9 fs	2/13/24 1	1:55 jma		No MC
Analysis Method: EPA 200.8 Rev. 5.4 Batch: T147101									
Arsenic	Not Detected	0.0022	mg/L	2/12/24 8:3	9 ckd	2/13/24 1	1:55 dminth	I-F	No MC
METALS, TOTAL									
Analysis Method: Calculation Batch: [CALC]									
Hardness as CaCO3	120	2.6	mg/L	2/12/24 8:3	9	2/13/24 1	1:55 jma	Ν	No MC
WET CHEMISTRY									
Analysis Method: EPA 300.0 Rev. 2.1 Batch: T147079									
Fluoride	Not Detected	0.10	mg/L	2/9/24 15:02	2 aeo	2/10/24	3:42 aeo	Ν	No MC
Chloride	43	10	mg/L	2/9/24 15:02	2 aeo	2/10/24	3:42 aeo		No MC
Nitrate as N	Not Detected	0.10	mg/L	2/9/24 15:02	2 aeo	2/10/24	3:42 aeo		No MC
Nitrite as N	Not Detected	0.10	mg/L	2/9/24 15:02	2 aeo	2/10/24	3:42 aeo		No MC
Sulfate as SO4	6.5	3.0	mg/L	2/9/24 15:02	2 aeo	2/10/24	3:42 aeo		No MC

#### **CERTIFICATE OF ANALYSIS**

#### STATE OF MICHIGAN LABORATORY ID: 8001